

समाहर्तृलय
Collectorate
Daman & Diu

No.DFES/SFO/DNH/Public Notice/2010/ 511
Deptt. of Fire & Emergency Services,
Dadra and Nagar Haveli, (U.T.),
Silvassa, Dtd.: 20/10/2010.

आदेश क्र. 699/.....
Date: 27/10/2010

PUBLIC NOTICE

It is brought to the notice of all concerned that, (1) Buildings 15 mtrs. and above in height (2) Factories and Establishments, where electric motor capacity exceeds 5 HP and above. (3) Shipyard and Workshops (4) Tank Farms of Petroleum Products/POL dispensing outlets (5) Flammable Gas/Godown/LPG Gas Godowns. (6) Godown and Ware houses (7) Public places like Exhibition, Halls, Entertainment place, Dancing Halls, Theatres, Assembly Halls, Sea Port, Air Port, Railway Station, Bus Station, Stadium etc. (8) Educational and Institutional places (9) Hotel, Restaurant and Bakeries and (10) Storage place of flammable and Hazardous goods are required to take Fire Prevention and Fire Safety measures/Installation of Fire Fighting System as provided in the National Building Code of India Part - IV (Fire Protection) and as per Notification issued by the U.T. Administration of Daman & Diu and Dadra & Nagar Haveli as mentioned below and as applicable to a particular case as per code.

1. Adequate means of access and Exits requirements;
2. Under ground/Overhead water storage tank;
3. Fire Service Standard inlet connection;
4. First Aid Hose Reel;
5. Automatic Sprinkler System;
6. Installation of Fire Extinguishers of ISI Certification Mark;
7. Compartmentation;
8. Automatic Fire detection and Fire Alarm System/Manually Operated Fire Alarm System (MOFA);
9. Illuminated Exit way marking signs;
10. Fire check doors and Fire Resistance doors;
11. Public Address System;
12. Alternative source of electric supply;
13. Fire Lift with Fireman Switch;
14. Wet riser- cum - Down Comer System;
15. Explosion suppression/Venting System.

All the relevant establishment should comply the above within a period of 90 days and apply for the NOC of the department of Fire and Emergency Services failing which the concerned establishment/premises shall be declared unsafe from Fire Safety point of view and concerned department will be intimated to withdraw the Government facilities provided/extended to them. Necessary guidance can be had from the Fire Station Silvassa/Daman in this regards.

Failure to comply may also result in Seizure, detention and removal of objects/goods likely to cause risk of fire under sub-Section (2) of section 13 of Goa, Daman & Diu, Fire Force Act, 1986 as extended to the U.Ts. of Daman and Diu and Dadra & Nagar Haveli

[Signature]
20.10.10
IGP/Director of Fire & Emergency Services,
Dadra and Nagar Haveli,
Silvassa.

Copy for necessary action to;

1. The P. S. to Hon. Administrator, DNH, Silvassa/Daman/Diu
2. The Collector, DNH, Silvassa/Daman/Diu
3. The PDA, DNH, Silvassa, ATP Daman/Diu
4. The Manager, DIC, DNH, Silvassa/Daman/Diu
5. The Chief Officer, SMC, DNH, Silvassa/Daman/Diu
6. The Executive Engineer, Electricity Deptt. DNH, Silvassa/Daman/Diu
7. The Chief Inspector of Factories & Boiler, DNH, Silvassa/Daman/Diu
8. The Purchase and Supply Officer, DNH, Silvassa/Daman/Diu
9. The Labour and Employment Officer, DNH, Silvassa/Daman/Diu
10. The Chief Publicity Officer, Dadra and Nagar Haveli for vide publicity and Publication in the News Paper and Electronic Media in DNH/Daman/Diu
11. The Station Fire Officer, Silvassa.
12. The Station Fire Officer, Daman.

NIC ✓

P. upload
on website
also
Notice Board.

[Signature]
18.11.10